

CITY OF CANEY
Consumer Confidence Report – 2023
Covering Calendar Year – 2022



This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affect drinking water quality, please call AMBER DEAN at 620-879-2772.

Your water comes from :

Source Name	Source Water Type
NEW INTAKE, LITTLE CANEY RIVER	Surface Water
OLD INTAKE, LITTLE CANEY RIVER	Surface Water

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA’s Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of

sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA’s regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system is required to test a minimum of 4 samples per month in accordance with the Revised Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2022 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2022. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. **The bottom line is that the water that is provided to you is safe.**

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Secondary Maximum Contaminant Level (SMCL): recommended level for a contaminant that is not regulated and has no MCL.

Action Level (AL): the concentration of a contaminant that, if

exceeded, triggers treatment or other requirements.

Treatment Technique (TT): a required process intended to reduce levels of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND): lab analysis indicates that the contaminant is not present.

Parts per Million (ppm) or milligrams per liter (mg/l)

Parts per Billion (ppb) or micrograms per liter (µg/l)

Picocuries per Liter (pCi/L): a measure of the radioactivity in water.

Millirems per Year (mrem/yr): measure of radiation absorbed by the body.

Monitoring Period Average (MPA): An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

Nephelometric Turbidity Unit (NTU): a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

Running Annual Average (RAA): an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Locational Running Annual Average (LRAA): Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Testing Results for: CITY OF CANEY

Microbiological	Result	MCL	MCLG	Typical Source
COLIFORM (TCR)	In the month of November, 2 sample(s) returned as positive	Treatment Technique Trigger	0	Naturally present in the environment

Regulated Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	4/4/2022	0.061	0.061	ppm	2	2	Discharge from metal refineries
CHROMIUM	4/4/2022	1.2	1.2	ppb	100	100	Discharge from steel and pulp mills
NITRATE	4/4/2022	0.68	0 - 0.68	ppm	10	10	Runoff from fertilizer use
SELENIUM	4/4/2022	1.7	1.7	ppb	50	50	Erosion of natural deposits

Disinfection Byproducts	Monitoring Period	Highest RAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	2022	4	0 - 3.8	ppb	60	0	By-product of drinking water disinfection
TTHM	2022	78	45 - 94	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90 th Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2020 - 2022	0.21	0.006 - 0.3	ppm	1.3	0	Corrosion of household plumbing
LEAD	2020 - 2022	3	0 - 3.4	ppb	15	0	Corrosion of household plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
2022 - 2022	2.6000	MG/L	2.1	MG/L

Total Organic Carbon Lowest Month for Removal	Number of Samples	Actual Removal Ratio	Required Removal Ratio	Lowest Monthly Removal Ratio
9/1/2022 - 9/30/2022	12	1.00	1.0 RATIO	0.29

Secondary Contaminants – Non-Health Based Contaminants - No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	4/4/2022	98	98	MG/L	300
ALUMINUM	4/4/2022	0.02	0.02	MG/L	0.05
CALCIUM	4/4/2022	43	43	MG/L	200
CHLORIDE	4/4/2022	31	31	MG/L	250
CONDUCTIVITY @ 25 C UMHOS/CM	4/4/2022	370	370	UMHO/C M	1500
CORROSIVITY	4/5/2021	0.38	0.38	LANG	0
HARDNESS, TOTAL (AS CaCO3)	4/4/2022	130	130	MG/L	400
MAGNESIUM	4/4/2022	5.6	5.6	MG/L	150
MANGANESE	4/4/2022	0.013	0.013	MG/L	0.05
NICKEL	4/4/2022	0.0032	0.0032	MG/L	0.1
PH	4/4/2022	7.4	7.4	PH	8.5
POTASSIUM	4/4/2022	2.9	2.9	MG/L	100
SILICA	4/4/2022	5.1	5.1	MG/L	50
SODIUM	4/4/2022	14	14	MG/L	100
SULFATE	4/4/2022	37	37	MG/L	250
TDS	4/4/2022	210	210	MG/L	500
ZINC	4/4/2022	0.034	0.034	MG/L	5

Please Note: Because of sampling schedules, results may be older than 1 year.

During the 2022 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
8/1/2022 - 8/31/2022	CHLORINE	MONITORING, ROUTINE (DBP), MAJOR
4/1/2022 - 4/30/2022	CHLORAMINE	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)
8/1/2022 - 8/31/2022	CHLORAMINE	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)


Additional Required Health Effects Language:

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other potentially harmful bacteria may be present.

Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

See following page regarding Important Information About Your Drinking Water: Monitoring Report Requirement Not Met for the City of Caney



CITY OF CANEY

100 W 4th Ave P.O. Box 129 Caney, Kansas 67333

Phone: (620) 879-2772

www.caneyks.com

Fax: (620) 879-9808

City Administrator – Kelly Zellner

Mayor – Joshua Elliott

Ref: Important Information About Your Drinking Water: Monitoring Report Requirement Not Met for the City of Caney
Dear Customer,

Our water system incurred a drinking water violation. Even though this was not an emergency, as our customers you have a right to know what happened and what we did to correct the situation. We did not submit on time a required report to the Kansas Department of Health and Environment (KDHE). Failure to submit the monitoring report on time is a violation of Federal and Kansas regulations and requires us to distribute this public notice to our customers.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether our drinking water meets health standards. Monitoring for turbidity (cloudiness) tells us whether we are effectively filtering the water supply. Monitoring for disinfectant residual in the water tells us whether we are effectively disinfecting the water supply. Disinfectant residual is the amount of chlorine or related disinfectant present in the pipes of the distribution system. If the amount of disinfectant is too low, organisms could grow in the pipes.

Each monthly report is due to KDHE 10 days after the last day of the month. KDHE received our report for January 2023 on February 27, 2023.

What does this mean?

- This is not an emergency. If it had been, you would have been notified within 24 hours. We incurred a violation because we were late in submitting reports to KDHE, and by law we are required to distribute a notice of this violation to our customers.

What should I do?

- There is nothing you need to do at this time.

What happened? What is being done?

- KDHE has received the April 2022 report. We are now returned to a status of "in compliance" for submitting the report. No further actions are required for this violation except for distributing this public notice to our consumers.

For more information, please contact Name: Amber Dean, City Clerk at Phone: [620-879-2772](tel:620-879-2772) Or by Mail: 100 W 4TH AVE, PO BOX 129, CANEY, KS 67333

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Thanks,

Amber Dean

City Clerk

100 W 4th Ave

Caney, KS 67333

620.879.2772

cityclerk@caney.kscoxmail.com

This notice is being sent to you by
CANEY, CITY OF, KS.

Federal ID#: KS2012517